



INDICATING BUTTERFLY VALVE

Suggested Specifications

(Underwriters Laboratory Listed and FM Approved)

1. Butterfly valves for above ground use shall be of the indicating type with a highly visible yellow flag on the valve actuator which indicates whether the valve is open or closed.
2. The valve actuator shall be a traveling nut type and have an input rating of 450 ft. lbs. of torque against the input stops.
3. Externally, the actuator shall be driven by a crank or 2" nut which is affixed to the input shaft by a shear pin.
4. Butterfly valves shall be Pratt Indicating Butterfly Valves Underwriters Laboratory listed and Factory Mutual approved as manufactured by us.
5. Valves shall be manufactured in accordance with AWWA C504-94, Class 150B.

For more information about Pratt or to view our full line of water products, please visit www.prattvalve.com or call Pratt customer service at 1.800.423.1323.

Mueller refers to one or more of Mueller Water Products, Inc., a Delaware corporation ("MWP"), and its subsidiaries. MWP and each of subsidiaries are legally separate and independent entities when providing products and services. MWP does not provide products or services to third parties. MWP and each of its subsidiaries are liable only for their own acts and omissions and not those of each other. MWP brands include Mueller®, Echologics®, Hydro Gate®, Hydro-Guard®, Jones®, Mi.Net®, Milliken®, Pratt®, Singer®, and U.S. Pipe Valve & Hydrant. Please see www.muellerwp.com/about to learn more.

Copyright © 2018 Henry Pratt Company, LLC. All Rights Reserved. The trademarks, logos and service marks displayed in this document are the property of Mueller Water Products, Inc., its affiliates or other third parties. Products marked with a section symbol (§) are subject to patents or patent applications. For details, visit www.mwppat.com. These products are intended for use in potable water applications. Please contact your Mueller Sales or Customer Service Representative concerning any other application(s).