


VIEW A-A



COUPLING ARRANGEMENT

NOTES:

1. ALL DIMENSIONS SHOWN IN INCHES.
2. ALL ITEMS ARE SHIPPED LOOSE FROM VALVE ASSEMBLY.
3. FIELD ASSEMBLY IS REQUIRED BY OTHERS.
4. SLIDING ARM TO BE CUT AS REQUIRED FOR EXTENSION STEMS LOCATED 13" TO 20" FROM WALL IN FIELD BY CUSTOMER.
5. COUPLING FURNISHED FOR 20'-0" LENGTHS AND ABOVE.

REV	DATE	BY	DESCRIPTION	APP.
PRATT <small>HENRY PRATT COMPANY AURORA, ILL.</small>			ADJUSTABLE STEADY BEARING FOR EXTENSION STEM	
SCALE		NONE	DATE 7-26-05	
DRAWN BY		ES	CHECKED BY <i>JW</i>	
APPROVED		GA-BORDER		
DRWG NO. GA-11456				REV 0 ^{A/C}