

SUGGESTED SPECIFICATIONS

RUBBER SEATED BUTTERFLY VALVE SIZES, 3"-20"

PRATT[®]
a **MUELLER** brand

General

Butterfly valves shall be manufactured in accordance with the latest revision of AWWA C504, Class 150B and conform to ANSI/NSF Standard 61 and 372. The manufacturer shall have produced AWWA butterfly valves for a minimum of five years. All valves shall be either Henry Pratt Model 2FII or Monoflange MKII as manufactured by the Henry Pratt Company

Valve Body

Valve bodies shall be constructed of ASTM A536, Class B ductile iron for flanged valves style. Flanged valves shall be fully faced and drilled in accordance with ANSI Standard B16.1, Class 125.

Valve Seats

Rubber body seats shall be of one piece construction, simultaneously molded and bonded into a recessed cavity in the valve body. Seats may not be located on the disc or be retained by segments and/or screws. For wafer style valves, the seat shall cover the entire inner surface of the valve body and extend over the outside face of the valve body to form a flange gasket.

Valve Bearings

Valve bearings shall be of a self-lubricating, nonmetallic material to effectively isolate the disc-shaft assembly from the valve body. Metal-to-metal thrust bearings in the flow stream are not allowed.

Valve Disc

The disc shall be a lens-shaped design to afford minimal pressure drop and line turbulence.

Materials of construction shall be:

- 3"-6" — ASTM A351 gr. CF8N stainless steel disc
- 8"-20" — ASTM A536, Class B ductile iron disc with a stainless steel type 316

Disc edge shall be retained by stainless steel pins which extend through the full diameter of the shaft to withstand the specified line pressure up to valve rating and the torque required to operate the valve. Disc stops located in the flow stream are not allowed.

Valve Shafts

Valve shafts shall be of stainless steel type 316. At the operator end of the valve shaft, a shaft seal utilizing "V" type chevron packing shall be utilized. "O" ring and/or "u" cup packing is not allowed.

Painting

All surfaces of the valve interior shall be clean, dry and free from grease before painting. The valve interior and exterior, except for disc edge, rubber seat and finished portions shall be evenly coated with an NSF61 approved 2-part liquid or Fusion Bonded epoxy. Minimum dry film thickness shall be 8 Mils minimum.

MUELLER[®] | **ECHOLOGICS**[®] | **HYDRO GATE**[®] | **HYDRO-GUARD**[®] | **JONES**[®] | **MI.NET**[®] | **MILLIKEN**[®] | **PRATT**[®] | **SINGER**[®] | **U.S. PIPE VALVE & HYDRANT**

1.800.423.1323 - www.prattvalve.com - moreinfo@muellercompany.com

INTERNATIONAL - 1.423.490.9555 - www.mueller-international.com - international@muellercompany.com

Mueller refers to one or more of Mueller Water Products, Inc., a Delaware corporation ("MWP"), and its subsidiaries. MWP and each of subsidiaries are legally separate and independent entities when providing products and services. MWP does not provide products or services to third parties. MWP and each of its subsidiaries are liable only for their own acts and omissions and not those of each other. MWP brands include Mueller[®], Echologics[®], Hydro Gate[®], Hydro-Guard[®], Jones[®], Mi.Net[®], Milliken[®], Pratt[®], Singer[®], and U.S. Pipe Valve & Hydrant. Please see www.muellerwp.com/about to learn more.



Copyright © 2018 Henry Pratt Company, LLC. All Rights Reserved. The trademarks, logos and service marks displayed in this document are the property of Mueller Water Products, Inc., its affiliates or other third parties. Products above marked with a section symbol (§) are subject to patents or patent applications. For details, visit www.mwppat.com. These products are intended for use in potable water applications. Please contact your Mueller Sales or Customer Service Representative concerning any other application(s).